

WATER CONSTRUCTION NOTES

1. ALL CONSTRUCTION SHALL CONFORM TO THE CITY OF UKIAH SPECIFICATION, CITY OF UKIAH STANDARD DRAWINGS, CALIFORNIA PLUMBING CODE (LATEST EDITION) AND AWWA STANDARDS.
2. THE CONTRACTOR SHALL PROVIDE, PROCURE AND PAY FOR ALL PERMITS REQUIRED TO CARRY ON AND COMPLETE THE WORK. THESE INCLUDE, BUT NOT LIMITED TO, ENCROACHMENT PERMITS, INSPECTION FEES, BUSINESS LICENSE, VALID AND PROPER CONTRACTOR'S LICENSE. ENCROACHMENT PERMITS MUST BE LOCATED ON THE JOB SITE DURING WHICH TIME CONTRACTOR IS WORKING THERE.
3. CONTRACTOR SHALL NOTIFY UNDERGROUND SERVICE ALERT (U.S.A.) TWO (2) WORKING DAYS PRIOR TO ANY EXCAVATION. DIAL (TOLL FREE) 1 - 800 - 227 - 2600.
4. ALL CONNECTIONS TO LIVE WATER MAINS SHALL BE MADE BY CITY FORCES, AT DEVELOPER'S EXPENSE.
5. CONSTRUCTION MATERIAL AND EQUIPMENT SHALL BE NEW AND OF A QUALITY EQUAL TO THAT SPECIFIED OR APPROVED. WORK SHALL BE DONE AND COMPLETED IN A THOROUGH AND WORKMANLIKE MANNER.

WHENEVER ANY MATERIAL OR EQUIPMENT IS INDICATED OR SPECIFIED BY PATENT OR PROPRIETARY NAME OR BY THE NAME OF THE MANUFACTURER, SUCH SPECIFICATION SHALL BE CONSIDERED AS DESCRIBING THE MATERIAL OR EQUIPMENT DESIRED AND SHALL BE FOLLOWED BY THE WORDS "OR APPROVED EQUAL ". THE CONTRACTOR MAY OFFER ANY MATERIAL OR EQUIPMENT WHICH SHALL BE EQUAL IN EVERY RESPECT TO THAT SPECIFIED; PROVIDED, THAT WRITTEN APPROVAL FIRST IS OBTAINED FROM THE CITY ENGINEER.

6. AT THE LOCATION OF EACH WATER AND SEWER SERVICE LATERAL, THE LETTERS "W" FOR WATER AND "S" FOR SEWER SHALL BE INSCRIBED INTO THE FACE OF THE CURB. THE LETTERS "W" AND "S" SHALL BE 4" HIGH AND COMPLETELY LEGIBLE.
7. METER BOXES AND VAULTS SHALL BE LOCATED OUT OF TRAFFIC LOADING AREAS WHENEVER POSSIBLE AND SET SO THAT THE READING LIDS ARE ALIGNED OVER THE METER REGISTERS AS CLOSELY AS POSSIBLE.

CITY OF UKIAH			
WATER CONSTRUCTION NOTES			
SCALE:	DRAWN BY:	DATE: 2/9/00	DRAWING NO.
APPROVED BY: <i>B. Bertelsen</i>			300