



NOTES

GATE VALVES SHALL BE OPERATED BY CITY WATER DEPARTMENT PERSONNEL ONLY.

BYPASS METER	
D.C. SIZE	METER SIZE
4" & 6"	5/8" & 3/4"
8"	" "
10"	" "

OPTIONAL VAULT SIZE'S		
D.C.	WIDTH	LENGTH
4"	4'	4'
6"	"	5'
8"	"	5'
10"	"	5'

CITY OF UKIAH

TYPICAL FIRE SPRINKLER
SERVICE INSTALLATION

4" THRU 10"

Scale: NTS
Date: 3/96
Drawn By: SK
Revised: TM.
Approved By: R. Kennedy
Drawing No. 314